

**PWSID# NJ0821001**

**Annual Drinking Water Quality Report**  
**Borough of Westville Water Department**  
**For the Year 2016, Results from the Year 2015**

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. We have 3 wells that draw groundwater from the Potomac-Raritan-Magothy Aquifer over 300 feet deep.

The New Jersey Department of Environmental Protection (NJDEP) has completed and issued the Source Water Assessment Report and Summary for this public water system, which is available at [www.state.nj.us/dep/swap](http://www.state.nj.us/dep/swap) or by contacting NJDEP's Bureau of Safe Drinking Water at (609) 292-5550. You may also contact your Westville Water Dept. at 856-456-7785 to obtain information regarding your water system's Source Water Assessment.

**We are pleased to report that our drinking water meets all federal and state safety requirements.** This report shows our water quality and what it means. We want our customers to be informed about their water utility. If you want to learn more, please attend our regularly scheduled council meetings located at 165 Broadway. Meetings are held the second Mondays of each month at 7:00 pm.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

EPA requires monitoring for over 80 drinking water contaminants. Those contaminants listed in the table are only contaminants detected in your water.

<b>TEST RESULTS</b>						
<b>Contaminant</b>	<b>Violation Y/N</b>	<b>Level Detected</b>	<b>Units of Measurement</b>	<b>MC LG</b>	<b>MCL</b>	<b>Likely Source of Contamination</b>
<b>Microbiological Contaminants</b>						
Total Coliform Bacteria	No	0/100 ml	P/A	N/A	0	Naturally present in the environment
<b>Radioactive Contaminants</b>						
Gross Alpha Test results 1/12/15	No	< 3.0	pCi/1	0	15	Erosion of natural deposits
Combined Radium- 228 & 226 Test results 1/12/15	No	< 1.0	pCi/1	0	5	Erosion of natural deposits
<b>Inorganic Contaminants: all results from 2012 unless noted</b>						
Barium 8/20/15	No	0.125	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Copper 7/15/14	No	0.8 no samples	ppm	1.3	AL=1.3	Corrosion of household

Result at 90 <sup>th</sup> Percentile		exceeded the AL				plumbing systems; erosion of natural deposits
Fluoride 8/20/15	No	0.174	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead Result at 90 <sup>th</sup> Percentile 7/15/14	No	0.0013 No samples exceeded the action level	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate (as Nitrogen) Tested 8/20/15	No	1.83	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
TTHM 8/20/15 Total Trihalomethanes	No	Range 2.41-42.8	ppb	N/A	80	By-product of drinking water disinfection
HAA5 8/20/15 Haloacetic Acids	No	Range 0 –5.10	ppb	N/A	60	By-product of drinking water disinfection

Regulated Disinfectants	Level Detected (Average & Highest Detect)	MRDL	MRDLG
Chlorine 2015	0.10- 0.40	4.0 ppm	4.0 ppm

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).**

Secondary Contaminant	Level Detected	Units of Measurement	RUL
Sodium 8/20/15	34.3	ppm	50

#### Sodium

For healthy individuals the sodium intake from water is not important, because a much greater intake of sodium takes place from salt in the diet. However sodium levels above the Recommended Upper Limit (RUL) may be of concern to individuals on a sodium restricted diet.

The Westville Water Dept. routinely monitors for contaminants in your drinking water according to Federal and State laws. The tables show the results of the monitoring period from January 1, 2015 to December 31, 2015. The state allows monitoring for some contaminants less than once per year because the concentrations of these contaminants don't change frequently. Some of the data, through representative, are more than one year old.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence

of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

## **DEFINITIONS**

In the following table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**LEAD**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Pitman Water Dept. is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 second to 2 minutes before using water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water hotline or at <http://www.epa.gov/safewater/lead>.

The Safe Drinking Water Act regulations allow monitoring waivers to reduce or eliminate the monitoring requirements for asbestos, volatile organic chemicals and synthetic organic chemicals. Our system received monitoring waivers for asbestos and synthetic organic compounds.

**Special considerations regarding children, pregnant women, nursing mothers, and others:**

Children may receive a slightly higher amount of a contaminant present in the water than do adults, on a body weight basis, because they may drink a greater amount of water per pound of body weight than do adults. For this reason, reproductive or developmental effects are used for calculating a drinking water standard if these effects occur at lower levels than other health effects of concern. If there is insufficient toxicity information for a chemical (for example, lack of data on reproductive or developmental effects), an extra uncertainty factor may be incorporated into the calculation of the drinking water standard, thus making the standard more stringent, to account for additional uncertainties regarding these effects. In the cases of lead and nitrate, effects on infants and children are the health endpoints upon which the standards are based. Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

**We at Westville Water Dept. work hard to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call 856-456-7785 if you have questions. We ask that all of our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.**

### **SEWER MAINTENANCE**

The Borough of Westville is responsible for maintaining wastewater flow in the sanitary sewer system. The line that connects a house or building to the Borough system is called a lateral. If a blockage occurs causing a backup, the borough encourages residents to call so we can verify whether the sewer main or lateral is obstructed. If the main is clear the property owner will be notified of the need to call a plumber to clear the service lateral.

**All property owners are responsible for the service lateral from the house/building to the sewer main.**

**Many things clog sewer pipes such as grease, roots, sanitary products, sticks, paper towels, Baby wipes, etc. Blockages can be avoided by not flushing anything but toilet paper. If you Have any questions, please call us @ 856-456-7785**

**PLEASE CONTINUE TO CONSERVE WATER. ALL NON ESSENTIAL USE IS TO OCCUR ON AN ODD/EVEN BASIS.**